



ADDENDUM #2

JOSEPHINE PANKEY COMMUNITY CENTER
13700 CANTRELL ROAD.
LITTLE ROCK, AR. 72212
May 12, 2015

TO: ALL BIDDING CONTRACTORS

The following items will become part of the Specification and Contract Documents. All provisions of the original Specifications and Contract Documents shall remain in full force and affect, except as modified by this addendum.

1. See Architectural Sheet A1.05 Reflected Ceiling Plan – Addendum #02
2. See Architectural Sheet A4.01 Floor Finish – Addendum #02
3. Attic Finish Floor Elevation – 10'-0" – To be verified
4. "Mechanical Contractor and Electrical Contractor shall refer to Architectural Reflected Ceiling Plan drawing, A1.05, for ceiling types. Ceiling type in Line-Up Room 65, Corridor 46 have changed from lay-in style ceilings to gyp board ceilings."
5. "Mechanical Contractor shall refer to Architectural Reflected Ceiling Plan drawing, A1.05, for ceiling types project-wide. Current Air Device Schedule on drawing M1.00 indicates that most ceiling types are Lay-In. Contractor shall review Architectural ceiling plans and provide correct type of grille per ceiling style."
6. See Mechanical Sheet M2.00 Mechanical Plan – Addendum #02
7. See Electrical Sheet E3.01 Floor Plan – Lighting – Addendum #02
8. See Electrical Sheet E4.01 Floor Plan – Elec. Demo. & Power – Addendum #02
9. See Electrical Sheet E7.01 Electrical Riser & Details – Addendum #02