

Addendum #1  
Partial Re-Roof of Homeless DRC  
3000 Confederate Blvd. Little Rock  
LR Bid #11-255  
January 5, 2012

Item #1 Refer Specifications, Attachment B ARRA Buy American: Bidders must be aware of ARRA requirements including Buy American regulations as they pertain to this bid. Information included in the specifications and information issued by Debra Carreiro with the City during the pre-bid should be considered when bidding. If there are questions concerning Buy American, contact Debra Carreiro at 501-399-3447.

Item #2 Refer to Drawing A-1:

- A. The cricket shown on the roof abutting the wall to the northwest is shown in no particular scale. This cricket, if constructed from metal, to match the rest of the roof, should have a slope the same or greater than the main roof. The cricket then would be shown to extend almost to the centerline ridge of the roof. This cricket can be constructed using other materials and methods, at the contractor's option. The warranty for this alternate method will match the warranty required on the metal roof.

Item #3 Refer to Specifications Section 13122 Metal Roofing Systems 2.04 and 2.05:

- A. The total roof system insulation required on this roof should provide an insulation value of R=19. This level of insulation can be attained by alternate methods to those described in the specification. The architect must approve the system before installation.